

Latrobe Valley BESS

Post-Construction Acoustic Assessment

S6828.1C12

October 2025

sonus.

Sonus Pty Ltd
17 Ruthven Ave
Adelaide SA 5000
Phone: +61 (8) 8231 2100
Email: info@sonus.com.au
www.sonus.com.au

Document Title : Latrobe Valley BESS
Post-Construction Acoustic Assessment
Document Reference : S6828.1C12
Date : October 2025
Author : Chris Turnbull, MAAS – Registered Professional Engineer (Victoria)

© Sonus Pty Ltd. All rights reserved.

This report may not be reproduced other than in its entirety. The report is for the sole use of the client for the particular circumstances described in the report. Sonus accepts no responsibility to any other party who may rely upon or use this report without prior written consent.

1 INTRODUCTION

The Latrobe Valley BESS (the **Facility**) is a battery energy storage system (**BESS**), located south of Morwell in Victoria. Phase 1A of the Facility (forming a portion of Stage 1) has recently been constructed in the location shown on Figure 1.



Figure 1: Subject Site and Locality

This report has been prepared to fulfill Condition 13 of the Planning Permit (Permit No. PA2101132-2, issued 16 November 2021) and outlines the results of the noise monitoring. The noise measurements were conducted in accordance with the Noise Compliance Assessment Procedure, summarised in the Sonus report with reference S6828.1C9, dated September 2025 (the **Procedure**). The Procedure has been based on the standard noise measurement procedure outlined in the EPA Publication 1826.4 *Noise limit and assessment protocol for the control of noise from commercial, industrial and trade premises and entertainment venues* (the **Noise Protocol**) with the goal of determining compliance with the noise limits set by the Noise Protocol.

2 CRITERIA

The base noise limits for the assessment of noise from facilities such as the BESS are set in Part 5.3 Division 3 of the *Environment Protection Regulations 2021* (the **Regulations**). The Regulations refer to the Noise Protocol for the assessment of noise. It is noted that Condition 11 of the Planning Permit also requires the Facility to comply with the requirements of the Noise Protocol. The Noise Protocol provides guidance in determining specific noise limits for new and existing commercial, industrial and trade premises in Victoria. For the purpose of this assessment, the rural area method (suitable for areas outside of the metropolitan area) has been employed.

The Noise Protocol provides a method to determine noise criteria for utilities in rural areas, based on the Victoria Planning Provisions zone of the noise source and nearby residences. The subject site is located within an Industrial 1 Zone (IN1Z) of the Victoria Planning Provisions, while the surrounding residences are located within a Farming Zone – Schedule 1 (FZ1). Based on this, the Noise Protocol defines zoning noise levels for different periods of the day. These are as follows:

- 53 dB(A) (L_{Aeq}) during the day¹;
- 48 dB(A) (L_{Aeq}) during the evening²; and,
- 43 dB(A) (L_{Aeq}) during the night³.

As the subject site and residences are located in different zones, the Noise Protocol requires a distance adjustment to be made to the zoning noise levels. This distance adjustment is based on the receiver distance, which is the distance the noise receiver is from the boundary of the Industrial 1 Zone. The distance adjustment reduces the zoning noise levels by 1 dB for every 100m of receiver distance, to a maximum reduction of 9 dB. The receiver distance and the distance adjustment factor for each residence can be seen in Table 1.

¹ 7:00am to 6:00pm Monday to Saturday, excluding public holidays.

² 6:00pm to 10:00pm Monday to Saturday and 7:00am to 10:00pm Sunday and public holidays.

³ 10:00pm to 7:00am the following day, any day of the week.

Table 1: Distance Adjustment Factors

Residence	Distance	Adjustment	Residence	Distance	Adjustment
Residence 1	80	0 dB(A)	Residence 8	570	5 dB(A)
Residence 2	360	3 dB(A)	Residence 9	530	5 dB(A)
Residence 3	400	4 dB(A)	Residence 10	590	5 dB(A)
Residence 4	130	1 dB(A)	Residence 11	640	6 dB(A)
Residence 5	240	2 dB(A)	Residence 12	90	0 dB(A)
Residence 6	480	4 dB(A)	Residence 13	110	1 dB(A)
Residence 7	370	3 dB(A)	Residence 14	100	1 dB(A)

Based on the above, the relevant noise limits are summarised in Table 2.

Table 2: Noise Protocol Noise Limits

Residence	Noise Limits		
	Day	Evening	Night
Residence 1	53 dB(A)	48 dB(A)	43 dB(A)
Residence 2	50 dB(A)	45 dB(A)	40 dB(A)
Residence 3	49 dB(A)	44 dB(A)	39 dB(A)
Residence 4	52 dB(A)	47 dB(A)	42 dB(A)
Residence 5	51 dB(A)	46 dB(A)	41 dB(A)
Residence 6	49 dB(A)	44 dB(A)	39 dB(A)
Residence 7	50 dB(A)	45 dB(A)	40 dB(A)
Residence 8	48 dB(A)	43 dB(A)	38 dB(A)
Residence 9	48 dB(A)	43 dB(A)	38 dB(A)
Residence 10	48 dB(A)	43 dB(A)	38 dB(A)
Residence 11	47 dB(A)	42 dB(A)	37 dB(A)
Residence 12	53 dB(A)	48 dB(A)	43 dB(A)
Residence 13	52 dB(A)	47 dB(A)	42 dB(A)
Residence 14	52 dB(A)	47 dB(A)	42 dB(A)

It is noted that these criteria are for the cumulative noise from all industrial noise sources in the vicinity. One way of demonstrating compliance with these criteria is for the contribution of noise from the Facility to be at least 10 dB(A) lower than the levels in Table 2, as this would demonstrate that the noise from the Facility is not contributing to noise at the cumulative limit at residences.

3 MEASUREMENT PROCEDURE

Attended noise measurements were taken on the night of the 2nd of September 2025. Measurements were initially taken near to the most exposed residence, Residence 1. Where the noise level is affected by atmospheric conditions, clause 76 of the Noise Protocol requires an alternate assessment location to be used, as stated below:

Where the effective noise level at the noise sensitive area is likely to be affected by atmospheric conditions, an alternative assessment location located near to the commercial, industrial or trade premises must be used unless there is no appropriate alternative assessment location (refer clause 77).

An alternate assessment location, M1, was therefore chosen that was downwind from the Subject Site. Due to high levels of extraneous noise at this location, additional noise measurements were taken at a second location, M2, which is still noted to be located downwind from the Facility. The locations where the measurements were taken can be seen in Table 3 and graphically in Figure 2. The proposed load profile and noise testing periods are detailed in the table in Appendix A.

Table 3: Measurement Locations

Location	Coordinates (UTM WGS84 55H)	
	Easting	Northing
R1	449369	5765332
M1	449357	5765305
M2	450746	5764399



Figure 2: Measurement Locations

Noise measurements were taken using a Rion NL-53 sound level meter (serial number 00240810), last calibrated on 4 March 2024. The calibration certificate and datasheet for the sound level meter can be seen in Appendix B. The sound level meter was placed on a tripod to facilitate the measurements, with a typical measurement setup shown in Figure 3. The sound level meter was calibrated before and after the noise measurements to a level of 94.0 dB(A) with no significant drift observed. The measurements were taken using the 'fast' time weighting and 'A' frequency weighting.



Figure 3: Typical Measurement Setup

It is noted that the operation of the Facility was inaudible while conducting the measurements at R1, with noise from other industry being the dominant noise source observed, as well as some influence from natural noise sources such as frogs. Therefore, measurements were subsequently taken at an alternate assessment location positioned closer to the site. Facility operations were the dominant noise source at this alternate location, though there was a significant contribution from frogs and potentially insects. The measurements were paused to remove the effects of extraneous noise, primarily from traffic.

4 MEASUREMENT RESULTS

The results of the measurements and the atmospheric conditions at the time of the measurements can be seen in Table 4. The atmospheric conditions have been taken from the nearest Bureau of Meteorology station to the Subject Site, being the station at the Latrobe Valley Airport. The observations for the time closest to the start of the measurement have been reported.

Table 4: Measurement Results

Measurement Number	Measurement Location	Measurement Time	Measured Noise Level	Temperature	Humidity	Wind Speed	Wind Direction
1	R1	2/9 9:45pm	41 dB(A)	9.1°C	61%	2 km/h	NE
2	M1	2/9 9:50pm	49 dB(A)	8.2°C	65%	4 km/h	W
3	M2	2/9 10:15pm	48 dB(A)	8.1°C	64%	2 km/h	W
4	M2	2/9 10:50pm	44 dB(A)	8.4°C	61%	7 km/h	SW
5	R1	2/9 11:05pm	43 dB(A)	8.4°C	61%	7 km/h	SW

In order to determine compliance based on the measurements taken at the alternate assessment location, the noise levels were extrapolated back to the primary assessment location, R1, using the alternate assessment criterion principles of the Noise Protocol. This was accomplished by comparing the predicted noise levels at these two locations. The results of this extrapolation can be seen in Table 5.

Table 5: Extrapolated Noise Levels

Measurement Number	Extrapolated Noise Level
2	24 dB(A)
3	24 dB(A)
4	19 dB(A)

The Noise Protocol requires the measured noise level to be adjusted for noise character where it is found to contain excessive tonality, impulsiveness, or intermittency. Observations taken at the alternate assessment location indicated that the noise produced by the facility was tonal in nature. The data for these measurements were then further analysed in accordance with the procedure outlined in Annex C of the Noise Protocol. This found that the noise was tonal in the 100 Hz, 200 Hz, 630 Hz, and 3.15 kHz one-third octave bands (though it is noted that the tone in the 3.15 kHz band is likely from frogs).

The measurements near to the residential location were also analysed for the presence of tonality in accordance with Annex C. While this did indicate that the noise was also tonal at this location, tones were only identified in the 80 Hz, 160 Hz, 315 Hz, 2 kHz, and 2.5 kHz one-third octave bands. None of the tones were in the same frequencies as those identified at the alternate assessment location. It can therefore be determined that the noise from the Facility does not exhibit tonality when considered at the nearest noise sensitive receiver.

The results of the measurements have also been extrapolated out to the other nearby noise sensitive receivers. The highest noise level at these locations can be seen in Table 6 alongside the relevant noise limits for only the contribution from the Facility (the relevant noise limits for the Facility are noted to be 10 dB(A) below the cumulative Noise Limit as per Table 2 and reproduced below).

Table 6: Extrapolated Noise Levels – All Residences

Residence	Extrapolated Noise Level	Cumulative Noise Limits	Facility Noise Limits
Residence 1	24 dB(A)	43 dB(A)	33 dB(A)
Residence 2	20 dB(A)	40 dB(A)	30 dB(A)
Residence 3	20 dB(A)	39 dB(A)	29 dB(A)
Residence 4	22 dB(A)	42 dB(A)	32 dB(A)
Residence 5	21 dB(A)	41 dB(A)	31 dB(A)
Residence 6	20 dB(A)	39 dB(A)	29 dB(A)
Residence 7	21 dB(A)	40 dB(A)	30 dB(A)
Residence 8	19 dB(A)	38 dB(A)	28 dB(A)
Residence 9	18 dB(A)	38 dB(A)	28 dB(A)
Residence 10	18 dB(A)	38 dB(A)	28 dB(A)
Residence 11	18 dB(A)	37 dB(A)	27 dB(A)
Residence 12	18 dB(A)	43 dB(A)	33 dB(A)
Residence 13	18 dB(A)	42 dB(A)	32 dB(A)
Residence 14	18 dB(A)	42 dB(A)	32 dB(A)

The results of the measurements indicate that the relevant noise limits determined in accordance with the Noise Protocol are easily achieved when considering the noise from the Facility.

5 CONCLUSION

Compliance noise monitoring was conducted on the 2nd of September 2025 for the recently constructed Phase 1A of the Latrobe Valley BESS, located south of Morwell in Victoria. Appropriate noise limits were determined in accordance with the Noise Protocol as required by the Planning Permit.

At the time of the noise monitoring, the noise from the BESS was not audible at the closest residence, even though it was located in a downwind direction under conditions conducive to noise propagation. Additional noise measurements were taken at an alternate assessment location in accordance with the Noise Protocol. The measured noise levels were then extrapolated to the location of the closest noise sensitive residence under worst-case meteorological conditions.

Based on the above, the measured noise levels from the Facility complied with the Noise Protocol and were sufficiently low to ensure that the noise from the Facility does not contribute to the overall noise level.



APPENDIX A: LOAD PROFILE

Time at end of dispatch window	P (MW)	Q (MVA _r)	Gen (MW)	Load(MW)	Planned HP Test	Energy Available (MWh)	No Inverters
20:30	-100	0	0	100	Commence charging at -100MW from approx 5% SoC	8.17	32
20:35	-100	0	0	100	Charge at full power prior to noise test	16.33	32
20:40	-100	0	0	100	Charge at full power prior to noise test	24.50	32
20:45	-100	0	0	100	Charge at full power prior to noise test	32.67	32
20:50	-100	0	0	100	Charge at full power prior to noise test	40.83	32
20:55	-100	0	0	100	Charge at full power prior to noise test	49.00	32
21:00	-100	0	0	100	Charge at full power prior to noise test	57.17	32
21:05	-100	0	0	100	Charge at full power prior to noise test	65.33	32
21:10	-100	0	0	100	Charge at full power prior to noise test	73.50	32
21:15	-100	0	0	100	Charge at full power prior to noise test	81.67	32
21:20	-100	0	0	100	Charge at full power prior to noise test	89.83	32
21:25	-100	0	0	100	Charge at full power prior to noise test	98.00	32
21:30	-100	0	0	100	Charge at full power prior to noise test	106.17	32
21:35	-100	0	0	100	Charge at full power prior to noise test	114.33	32
21:40	-100	0	0	100	Charge at full power prior to noise test	122.50	32
21:45	-100	0	0	100	Charge at full power prior to noise test	130.67	32
21:50	-100	0	0	100	Charge at full power prior to noise test	138.83	32
21:55	-100	0	0	100	Noise Testing - charge period commence noise tests	147.00	32
22:00	-100	0	0	100	Noise Testing - charge period commence noise tests	155.17	32
22:05	-100	0	0	100	Noise Testing - charge period commence noise tests	163.33	32
22:10	-100	0	0	100	Noise Testing - charge period commence noise tests	171.50	32
22:15	-100	0	0	100	Noise Testing - charge period commence noise tests	179.67	32
22:20	-100	0	0	100	Noise Testing - charge period commence noise tests	187.83	32
22:25	-100	0	0	100	Noise Testing - charge period commence noise tests	196.00	32
22:30	-100	0	0	100	Noise Testing - charge period commence noise tests	200.00	32
22:35	0	0	0	0	Pause	199.83	32
22:40	0	0	0	0	Pause	199.67	32
22:45	0	0	0	0	Pause	199.50	32
22:50	100	0	100	0	Noise Testing - discharge period commence noise tests	191.00	32
22:55	100	0	100	0	Noise Testing - discharge period commence noise tests	182.50	32
23:00	100	0	100	0	Noise Testing - discharge period commence noise tests	174.00	32
23:05	100	0	100	0	Noise Testing - discharge period commence noise tests	165.50	32
23:10	100	0	100	0	Noise Testing - discharge period commence noise tests	157.00	32
23:15	100	0	100	0	Noise Testing - discharge period commence noise tests	148.50	32
23:20	100	0	100	0	Noise Testing - discharge period commence noise tests	140.00	32
23:25	100	0	100	0	Noise Testing - discharge period commence noise tests	131.50	32
23:30	0	0	0	0	Resume normal operation	131.33	32

APPENDIX B: SOUND LEVEL METER DETAILS



3-20-41 Higashimotomachi Kokubunji Tokyo 185-8533
Phone:042(359)7888, Facsimile:042(359)7442

Certificate of Calibration

Name : Class 1 Sound Level Meter
Model : NL-53 **S/No.** : 00240810
Date of Calibration : March, 04, 2024

We hereby certify that the above product was tested and calibrated according to the prescribed Rion procedures, and that it fulfills specification requirements.
The measuring equipment and reference devices used for testing and calibrating this unit are managed under the Rion traceability system and are traceable according to official Japanese standards and official standards of countries belonging to the International Committee of Weights and Measures.

RION CO., LTD.

A handwritten signature in black ink, appearing to read 'J. Kawamura'.

Manager, Quality Control Department

■ Specifications

					
			Class 1 Sound Level Meter NL-63	Class 1 Sound Level Meter NL-53	Class 2 Sound Level Meter NL-43
Applicable standards			IEC 61672-1: 2013 class 1, ISO 7196: 1995, ANSI/ASA S1.4-2014/Part1 class 1, JIS C 1509-1:2017 class 1, JIS C 1516: 2020 class 1 ISO 7196: 1995 CE Marking • EMC Directive 2014/30/EU EN 61326-1:2013 • RoHS Directive 2011/65/EU EN IEC 63000:2018 • Low Voltage Directive 2014/35/EU EN 61010-1:2010/A1:2019 UKCA Marking, China RoHS, KC mark, VCCI Class B	IEC 61672-1: 2013 class 1, ANSI/ASA S1.4-2014/Part1 class 1, JIS C 1509-1:2017 class 1, JIS C 1516: 2020 class 1	IEC 61672-1: 2013 class 2, ANSI/ASA S1.4-2014/Part1 class 2, JIS C 1509-1: 2017 class 2, JIS C 1516: 2020 class 2
Measurement function			Simultaneous measurement of up to four conditions (Main channel, Sub1 to Sub3 channels) with selected time weighting and frequency weighting		
	Instantaneous value		Time-weighted sound pressure level L_p		
	Calculated value		Equivalent continuous sound level: L_{eq} , 1-time-weighted equivalent continuous sound level: L_{eq} , Moving L_{eq} : $L_{eq, mov}$ Sound exposure level: L_E , Maximum sound level: L_{max} , Minimum sound level: L_{min} , Percentile sound level: L_N Peak sound level: L_{peak} , Takt-max sound level: L_{tms}	Equivalent continuous sound level: L_{eq} , 1-time-weighted equivalent continuous sound level: L_{eq}^{*2} , Moving L_{eq} : $L_{eq, mov}^{*2}$, Sound exposure level: L_E , Maximum sound level: L_{max} , Minimum sound level: L_{min} , Percentile sound level: L_N , Peak sound level: L_{peak} , Takt-max sound level: L_{tms}	
Microphone	Type		UC-59L	UC-59	UC-52
	Sensitivity level (representative value)		-27 dB	-27 dB	-33 dB
Measurement level range			A-weighting: 25 dB to 138 dB, C-weighting: 33 dB to 138 dB, G-weighting: 43 dB to 138 dB, Z-weighting: 50 dB to 138 dB, C-weighted peak sound level: 60 dB to 141 dB, Z-weighted peak sound level: 65 dB to 141 dB	A-weighting: 25 dB to 138 dB, C-weighting: 33 dB to 138 dB, Z-weighting: 38 dB to 138 dB, C-weighted peak sound level: 55 dB to 141 dB, Z-weighted peak sound level: 60 dB to 141 dB	
Self-generated noise	A-weighting		17 dB or less	17 dB or less	19 dB or less
	C-weighting		25 dB or less	25 dB or less	27 dB or less
	Z-weighting		42 dB or less	30 dB or less	32 dB or less
	G-weighting		35 dB or less	—	—
Measurement frequency range			1 Hz to 20 kHz	10 Hz to 20 kHz	20 Hz to 8 kHz
Frequency weighting			A, C, G, Z	A, C, Z	
Filter			High-pass filter Low-pass filter Cutoff frequency: 100 Hz, 500 Hz	—	
Time weighting			F (Fast), S (Slow), I (Impulse), 10 s	F (Fast), S (Slow), I (Impulse)*2	
Input range			Automatic switching		
Bar graph display	Upper range		70 dB to 130 dB can be set in 10 dB increments		
	Lower range		20 dB to 60 dB can be set in 10 dB increments		
Sampling interval			L_p , L_{eq} , L_E , L_{max} , L_{min} , L_{peak} , L_{tms} : 20.8 μ s (Sampling frequency: 48 kHz), L_N : 100 ms (L_p), 1 s (L_{eq}), $L_{eq, mov}$: 1 s (L_{eq}), L_{tms} : 5 s (L_{max})		
Calibration			A reference signal is input using sound calibrator NC-75/NC-74 or pistonphone NC-72B/NC-72A, and the signal input sensitivity is adjusted. Up to 30 calibrations can be managed in the calibration history, and saved to an SD card		
Reference signal output to external devices	Frequency		1 kHz		
	Output level		Bar graph upper limit -6 dB		
Correction function	Windscreen correction function		Corrects the influence on the frequency response when the windscreen is installed.		
	Diffuse sound field correction function		Corrects the influence on the frequency response when used in a diffuse sound field.		
Delay time			After the operation to start measuring, the device starts measuring after the specified time elapses (OFF, 1, 3, 5, 10 s)		
Back erase function			Excludes, from the calculation, data from the specified time before using this function (OFF, 1, 3, 5 s, May not be used together with auto store mode and waveform recording)		
Display			Backlit 3.5-inch TFT-LCD QVGA *With touch panel function (resistive membrane type) Numerical display update frequency: 1 s, Graph showing time and sound level / bar graph refresh interval: 100 ms		
Store	Manual store		Data for measurement results are stored manually in single address increments.		
		Number of data	Internal memory: max. 1000 sets SD Card: depends on the capacity of the SD Card*1		
		Measurement time	10 s, 1, 5, 10, 15, 30 m, 1, 8, 24 h, User Setting (1 s to 24 h)		
	Auto store*2		Instantaneous values (L_p store) and processed values (L_{eq} store) are stored continuously on the SD card and automatically at preset intervals.		
		L_p store interval	Off, 10 ms, 25 ms, 100 ms, 200 ms, 1 s		
		L_{eq} calculation interval	Off, 10 s, 1, 5, 10, 15, 30, 1, 8, 24 h, or User Setting (Min. 1 s to max. 24 h)		
		Number of data	SD card: Data can be saved with store names from 0000 to 9999		
		Measurement time	10 s, 1, 5, 10, 15, 30, 1, 8, 24 h, User Setting (Min. 1 s to max 1000 h), Continue (Perform measurements until the SD card runs out of space*1)		

●● : Same content as NL-63

			●● : Same content as NL-63	
Data format	CSV file		●	●
Data recall	Browses stored data and screenshot images		●	●
Memorizing Settings	Setting information can be saved to the internal memory or SD card and recalled at startup or at a specified time		●	●
Waveform recording*2*3	File format	Uncompressed waveform WAVE file	●	●
	Sampling frequency	Select 48 kHz, 24 kHz, 12 kHz, 1200 Hz or 240 kHz	●	●
	Data length	Select 24 bit or 16 bit	●	●
Outputs	AC output	Output voltage: 1 V rms at the output level range	●	●
	DC output	Output voltage: 2.5 V, 25 mV/dB at the output level range	●	●
	Output range	Can be linked to the bar graph upper limit, or set from 70 dB to 130 dB in 10 dB increments	●	●
	Comparator*2	The comparator output turns on when the specified channel exceeds the set level	●	●
		(Maximum input voltage 24 V, internal resistance approx. 480 Ω, Allowable power dissipation 300 mW)	●	●
RS-232C Communication	Measurement values can be acquired and settings can be changed by using communication commands		●	●
USB	Communication	Measurement values can be acquired and settings can be changed by using communication commands	●	●
	Data transfer	Enables the transferring of data by making the computer recognize the SD card as a removable disk	●	●
LAN*2	Communication	Measurement values can be acquired and settings can be changed by using communication commands	●	●
	Data transfer	Data on an SD card can be transferred to a computer	●	●
	Web browser display	Via a web browser, settings can be changed and measured values displayed. Via Google Chrome on PC, audio can be played.*3	●	●
Data continuous output*2	Type of data	Instantaneous value I_p	●	●
		Processed value I_{avg} , I_{max} , I_{min} , I_{peak}	●	●
	Output interval	100 ms (0.1 s)	●	●
Power supply	4 × AA batteries, power supply to DC jack and USB port		●	●
	Operating time (at 23°C, ECO setting)	Alkaline battery LR6: Approx. 12 hours Ni-MH rechargeable battery HR6: Approx. 12 hours Portable charger: Approx. 20 hours of power at 5000 mAh *When making Auto store mode and ECO settings The operating time varies depending on the device settings and the battery manufacturer	Alkaline battery LR6: Approx. 16 hours Ni-MH rechargeable battery HR6: Approx. 16 hours Portable charger: Approx. 24 hours of power at 5000 mAh *When making Auto store mode*2 and ECO settings The operating time varies depending on the device settings and the battery manufacturer	●
	AC adapter	NE-21P (Input: 100 to 240 V AC, 50/60 Hz, Output: 12 V DC)	●	●
	External power supply voltage	5.7 V to 15 V (rated voltage 12 V) USB port: 5 V (See precautions on mobile battery usage)	●	●
	Primary side (100 V side) power consumption	Approx. 3 W (With NE-21P usage)	●	●
	Operating temperature and humidity range	Temperature: -10 °C to 50 °C Humidity: 10 % to 90 % RH (no condensation)	●	●
Dustproof and waterproof performance*4	IP rating: IP54 (excluding microphone)		●	●
Dimensions, weight	Approx. 265 mm (H) × 83.5 mm (W) × 34.5 mm (D), approx. 400 g (including batteries)		●	●
Accessories	Carrying case x1, Windscreen WS-10 x1, Windscreen fall prevention rubber x1, Hand strap x1, Size AA alkaline batteries x4, SD card 512 MB		●	●

Options

Product name	Product number	Compatible models
Extended Function Program (Inst.on 512 MB SD card)	NX-43EX	NL-43/53
Waveform Recording Program (Inst.on 2 GB SD card)	NX-43WR	NL-43/53/63
Octave-1/3 Octave Real-time Analysis Program (Inst.on 512 MB SD card)	NX-43RT	NL-43/53
Octave-1/3 Octave Real-time Analysis Program (Inst.on 512 MB SD card)	NX-63RT	NL-63
FFT Analysis Program (Inst.on 512 MB SD card)	NX-43FT	
512 MB SD Card	MC-51SD1	
2 GB SD Card	MC-20SD2	
32 GB SD Card	MC-32SP3	
AC adapter (100 V to 240 V AC)	NE-21P	
Battery pack (Using four D alkaline batteries)	BP-21A	
Microphone extension cable	EC-04 series	
BNC pin output cable	CC-24/CC-24S	NL-43/53/63
Printer cable	CC-42P	
RS-232C serial I/O cable	CC-42R	
Comparator Output / Trigger Input Cable	CC-43CT	
AC/DC Output Splitter Cable	CC-43S	
DC Polarity Converter	CC-43J	
USB cable (Type-C)	—	
Sound calibrator	NC-75	

Product name	Product number	Compatible models
Pistonphone	NC-72B	
Dedicated soft case	—	
Rubber cover for external power use	—	
All-Weather Windscreen	WS-15	NL-43/53/63
Windscreen mounting adapter	WS15006	
Rain-protection Windscreen	WS-16	
Tripod for sound level meter	ST-80	
Tripod extension rod (For ST-80)	ST-80-100	
Tripod for All-Weather Windscreen	ST-91	
Data Management Software for Environmental Measurement	AS-60	
Data Management Software for Environmental Measurement (Includes the Octave and 1/3 Octave Data Management Software)	AS-60RT	See p.8
Waveform Analysis Software	AS-70	

*1 Use Rion fully guaranteed products. *2 NX-43EX required for NL-43/NL-53 (sold separately) *3 NX-43WR required (sold separately).
*4 Protection against harmful dust and water splashing from any direction.

Precautions on portable charger usage

Avoid portable charger with functions that monitor device power consumption and are capable of interrupting the power supply.
The power consumption of NL-43/53/63 is relatively low compared to smartphones; portable charger equipped with such features may erroneously terminate power supply to the unit.